

## MONTH WISE MAXIMUM DEMAND OF POWER AT THE RESPECTIVE REGIONAL SUB-STATIONS

MD In MW

Sl. No	Month	230 KV Villianur SS	230 KV Thoanda manatham SS	230 KV Bahour SS	Total MD of 230 KV SS	TNEB power drawn at Pondy	Total for Pondy	MD of power drawn at Karaikal		Total for Karaikal	Mahe	Yanam 132 KV SS	Total for UT
					(3+4+5)		(5+6)	Sorakudy	PPCL	(8+9)			(7+10+13+14)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)
1.	04/15	112.70	137.00	97.70	347.40	0.00	347.40	62.01	32.00	94.01	7.00	10.25	<b>458.66</b>
2.	05/15	127.00	136.00	93.50	356.50	0.00	356.50	56.38	32.00	88.38	6.76	10.50	<b>462.14</b>
3.	06/15	132.90	127.00	99.90	359.80	0.00	359.80	41.24	32.00	73.24	6.78	10.90	<b>450.72</b>
4.	07/15	127.70	133.30	93.50	354.50	0.00	354.50	40.92	32.00	72.92	6.54	16.20	<b>450.16</b>
5.	08/15	123.80	130.80	94.90	349.50	12.19	361.69	38.99	32.00	70.99	6.38	11.80	<b>450.86</b>
6.	09/15	134.70	128.60	112.40	375.70	0.00	375.70	50.96	32.00	82.96	6.61	10.40	<b>475.67</b>
7.	10/15	123.20	136.90	94.90	355.00	0.00	355.00	43.95	32.00	75.95	6.62	10.50	<b>448.07</b>
8.	11/15	107.40	123.00	96.60	327.00	0.00	327.00	29.83	32.00	61.83	7.08	9.70	<b>405.61</b>
9.	12/15	107.40	125.00	90.10	322.50	0.00	322.50	21.61	32.00	53.61	6.80	9.10	<b>392.01</b>
10.	01/16	107.70	126.10	86.50	320.30	0.00	320.30	39.48	32.00	71.48	6.60	9.00	<b>407.38</b>
11.	02/16	115.00	125.00	92.30	332.30	0.00	332.30	32.53	32.00	64.53	6.64	9.05	<b>412.52</b>
12.	03/16	123.20	136.90	94.90	355.00	8.42	363.42	35.63	32.00	67.63	7.58	8.90	<b>447.53</b>
<b>Maximum Demand</b>		<b>134.70</b>	<b>137.00</b>	<b>112.40</b>	<b>375.70</b>	<b>12.19</b>	<b>375.70</b>	<b>62.01</b>	<b>32.00</b>	<b>94.01</b>	<b>7.58</b>	<b>16.20</b>	<b>475.67</b>